

Group B Design Workbook



Complete this workbook to satisfy the planning and design requirements needed to get approval for a new or expanding Group B water system

This workbook supports the Group B rule that goes into effect January 1, 2014.



DOH 331-468
December 2012

INTRODUCTION

Completing this *Group B Design Workbook* (workbook) will satisfy the design and planning requirements for a new or expanding Group B water system (WAC 246-291-120 and WAC 246-291-140, respectively).

If you're a professional engineer, and you are not comfortable using the workbook format, you may submit your design in an alternate format of your choosing. However, you must submit all the information referenced in this workbook and required by chapter 246-291 WAC.

Before sending your completed workbook to the reviewing agency, make copies of all plans, design drawings, worksheets, equipment information, operations and maintenance manuals, legal documents, and forms. Keep this information with your other project documents because it will help you and others successfully manage and operate your new water system.

Regulations

We suggest you become familiar with chapter 246-291 WAC and the information in the *Group B Water System Design Guidelines* (331-467) before you start your design. Chapter 246-291 WAC is Washington's Group B water system rule. You can view and download the Group B rule that was revised in 2012 and goes into effect January 1, 2014, at <http://www.doh.wa.gov/CommunityandEnvironment/DrinkingWater/RegulationandCompliance/Rules.aspx>

Group B Water System Design Guidelines

Use this workbook with the *Group B Water System Design Guidelines* (331-467). Even if you have a lot of experience designing small systems, we recommend you read the design guidelines before starting your design. We created the guidelines to support your goal of preparing a complete submittal that reflects sound water system design practices and established principles of public health protection.

The *Group B Water System Design Guidelines* will answer questions such as:

- When can't I develop my own Group B water system?
- When don't I need to get approval before I construct my water system?
- When must a professional engineer design the new or expanding system?
- Which water quality tests must I submit?
- How long must I run the pump test on my well?
- How do Washington's water rights laws affect my design?
- How big an easement should I have for my pipelines?
- What information must I include on the title of customers' properties?

Certain one and two-connection water systems are not regulated. Before submitting your Group B design workbook, see Section 2.1 of the *Group B Water System Design Guidelines* (331-467) to be sure your project design requires department approval.

You can view and download the *Group B Water System Design Guidelines* (331-467) online at <https://fortress.wa.gov/doh/eh/dw/publications/publications.cfm> To order the design guidelines on CD, click “Add to cart.” Due to budget constraints, we don’t have paper copies of the guidelines available for distribution.

Fees Charged for Workbook Design Reviews

A completed workbook addresses the planning, design report, and construction documents required by WAC 246-291-120 and -140.

- **If the local health jurisdiction is the reviewing authority**

Ask your local health department about the fees it will charge to review your workbook.

- **If the state Department of Health is the reviewing authority**

The department will charge applicants each of the following fees for a **new** Group B water system:

\$138 for a Water System Plan Review (WAC 246-290-990 (1)(a))

\$205 for a Design Report Review (WAC 246-290-990 (1)(d))

\$281 for a Construction Document Review (WAC 246-290-990 (1)(f))

Total fee = \$624

In addition to the fees above, the department will charge applicants for these services:

\$205 for a Well Site Evaluation (WAC 246-290-990 (1)(i))

Fee varies for a Secondary Treatment Design Review
(For amounts, see WAC 246-290-990 (1)(d) and (1)(f)).

Online Group B Resources

We developed online Group B resources to help you from the pre-submittal stage of your water system design through operation and maintenance. Before your new system becomes operational, we recommend you visit the Group B website at <http://www.doh.wa.gov/CommunityandEnvironment/DrinkingWater/WaterSystemAssistance/GroupB.aspx>



The *Online Group B Resources* have:

- All the forms you need to meet the submittal requirements for a new or expanding Group B water system, including the *Group B Project Approval Application Form*, *Water Facilities Inventory Form*, and examples of *Well sanitary control area protective covenants* forms.
- Guidance to help you operate and maintain your small system. After you receive written approval of your water system design, you may begin construction of the distribution system, well house, tanks, treatment equipment, and so forth. We urge you to review this information before you begin operating your new or expanded system.

Department of Health Contacts

Before beginning your Group B workbook, we strongly recommend that you contact your local health jurisdiction to find out whether the local or state health department administers the Group B program in your county. In the Group B workbook and in the *Group B Water System Design Guidelines*, the term "department" refers to the agency responsible for reviewing and approving a Group B water system design in your particular county.

Designers or design engineers with questions or concerns should contact the department. Table 1 presents contact information for the state Department of Health. You can get contact information for your local health jurisdiction from your local phone book.

Table 1**Office of Drinking Water Regional Offices**

If you have questions about this workbook, the *Group B Water System Design Guidelines*, the *Online Group B Resources*, or the State Board of Health Rules on Group B Public Water Systems, call our regional office or your local health jurisdiction.

Eastern Region	Serving
Drinking Water Eastern Regional Office 16201 E. Indiana Ave. Suite 1500 Spokane Valley, WA 99216 Phone: 509-329-2100 Fax: 509-329-2104 TDD Relay: 1-800-833-6388	Adams, Asotin, Benton, Chelan, Columbia, Douglas, Franklin, Ferry, Garfield, Grant, Kittitas, Klickitat, Lincoln, Okanogan, Pend Oreille, Spokane, Stevens, Walla Walla, Whitman, and Yakima counties.
Northwest Region	Serving
Drinking Water Northwest Regional Office 20425 - 72nd Avenue South Suite 310 Kent, WA 98032 Phone: 253-395-6750 Fax: 253-395-6760 TDD Relay: 1-800-833-6388	Island, King, Pierce, San Juan, Skagit, Snohomish, and Whatcom counties.
Southwest Region	Serving
Drinking Water Southwest Regional Office Physical: 243 Israel Road Tumwater, WA 98501 Mailing: P O Box 47823 Olympia, WA 98504-7823 Phone: 360-236-3030 Fax: 360-664-8058 TDD Relay: 1-800-833-6388	Clallam, Clark, Cowlitz, Grays Harbor, Jefferson, Kitsap, Lewis, Mason, Pacific, Skamania, Thurston, and Wahkiakum counties.

Group B Planning and Design Submittal Checklist

CHECKLIST FOR A NEW OR EXPANDING GROUP B WATER SYSTEM

Planning and Design Submittal Element	Group B Design Guidelines Section	Yes, Included	No, Not Applicable
Completed submittal checklist for a new or expanding Group B system			
Completed project approval application form	Section 2.2		
Property title notice	Section 2.6		
Service area map	Section 2.3		
Demonstrate compliance with SMA requirement <u>Applies to new systems only.</u>	Section 2.5		
Demonstrate compliance with PWS Coordination Act	Section 2.6		
Completed Water Facilities Inventory (WFI) (OPTIONAL)	Section 2.9		
Water users' agreement (OPTIONAL)	Section 2.8		
Water right permit	Section 3.0		
Well log	Section 4.1		
Well pump test report	Section 4.1		
Well water quality sampling results	Section 4.2		
Documentation of well site approval	Section 4.3		
Well sanitary control area protective covenants	Section 2.7 and 4.3		
Intertie agreement	Section 4.4		
Well and pump house detailed drawings and specifications	Section 5.2 and 5.3		
Distribution system detailed drawing and specifications	Section 6.10		
Storage tank sizing, detailed drawings, and specifications	Section 7.6		
Booster pump sizing, detailed drawings, and specifications	Section 8.1		
Secondary contaminant treatment design	Chapter 9		
Completed <i>Group B Design Report Workbook</i>			

GROUP B Design Report Workbook

1.0 Designer and Owner

Failure to complete all applicable sections of this workbook will result in denial of your application or delay in its approval. Please print all information.

1.1 Water System Designer

Workbook prepared by _____

Mailing Address _____

Company Name _____

Day Phone _____

If prepared by a Professional Engineer, apply seal here.

1.2 Water System Owner

Owner's Name _____

Owner's Mailing Address _____

Day Phone _____

Owner's Representative Signature _____ Date _____

2.0 Basic Water System Information

2.1 Water system name and location

System Name _____

Water System Location _____
(Town or City, County)

Public Water System ID# _____
(Applies only to existing systems seeking approval to expand)

2.2 Basic information

You **must** submit the following with this workbook:

- Completed Group B planning and design submittal checklist
- Completed project approval application form

The form is online at

<http://www.doh.wa.gov/CommunityandEnvironment/DrinkingWater/WaterSystemAssistance/GroupB/GroupBResources.aspx>

- Property title notice (the notice you intend to record on the title for each property served, see *Group B Water System Design Guidelines* Section 2.6)
- Service area map
- Demonstrated compliance with Satellite Management Agency requirement
See *Group B Water System Design Guidelines* Section 2.5.
- Demonstrated compliance with Public Water System Coordination Act
See *Group B Water System Design Guidelines* Section 2.4.

We recommend you include a completed *Water Facilities Inventory* form. See *Group B Water System Design Guidelines* Appendix E.

2.3 Connections and Population

See the requirements for establishing the design service population for each dwelling unit in WAC 246-291-200 (2). See Section 2.0 of the *Group B Water System Design Guidelines* for expectations on counting accessory dwelling units as separate connections.

Connections		Service Population	
Dwelling units	Nonresidential	Residential	Nonresidential

Use the space below to describe the basis for estimating your residential and nonresidential service population.

3.0 Estimating Water Demands

3.1 Complete Worksheet 3-1

Summary of Peak Hourly Demand (PHD) and Maximum Daily Demand (MDD) Summary

Worksheet 3-1

Line	Group B Design Guidelines Section	Description	Value
A	3.1.1, and 3.3	Total residential MDD, gallons per day	
B	3.1.2, and 3.3	Total residential PHD, gallons per minute	
C	3.2.1, and 3.3	Total non-residential MDD, gallons per day	
D	3.2.2, and 3.3	Total non-residential PHD, gallons per minute	
F-1	3.4	Fire suppression flow required (if any), gpm	
F-2	3.4	Fire suppression flow duration, minutes	

Total area intended for irrigation: _____ square feet or acres

Total system MDD (Lines A+C): _____ gallons per day

Total system PHD (Lines B+D+F1): _____ gallons per minute

Is a **water right permit** or other written Dept. of Ecology water resource approval required? See Section 3.0 of the *Group B Water System Design Guidelines*.

_____ Yes _____ No

If "Yes," enclose a copy of the water right permit or other written approval from the Department of Ecology.

Use the space below to show your calculations of estimated MDD and PHD:

4.0 Source of Supply

4.1 Well information

If a well will supply water to your system, you must attach the following to your design submittal:

- Well log
- Pump test report (See Section 4.1 of the *Group B Water System Design Guidelines*)
- Water quality sampling results (See Section 4.2 of the *Group B Water System Design Guidelines* and WAC 246-291-125 (3)(g))
- Well site inspection report prepared by DOH or the local health jurisdiction
- Well sanitary control area protective covenants (Attach a copy of the actual protective covenants filed with the County Auditor for each public drinking water well. See Sections 2.7 and 4.3 of the *Group B Water System Design Guidelines*.)
- Low yield well water supply contingency plan, if required. (See Section 4.1 of the *Group B Water System Design Guidelines*.)



4.2 Wellhead Protection Inventory

Please indicate whether any of the following are present within 600 feet of your well.

Potential Water Quality Threat	Yes	No	Unknown
Likely pesticide application			
Storm water injection wells			
Other injection wells			
Abandoned groundwater wells			
Landfills, dumps, disposal areas			
Known hazardous materials site			
Another water system with known water quality problems			
Residential development greater than one house per acre			
Residential septic tanks			
Underground storage tanks			
Sewer lines			
Storm water disposal areas			
Surface water – If yes, specify distance from well site: _____ feet			

Use this space to provide more detail of any water quality threat located within 600 feet of your well:

4.2 Intertie information

If an intertie will supply your system, you must attach a copy of your intertie agreement, and service capacity and hydraulic analyses of the wholesale system. For details about the minimum scope of an intertie agreement, see WAC 246-291-135.

5.0 Well Pump, Bladder Tanks, and Pump House

5.1 Piping Schematic

Draw a schematic of the piping system below. Begin with the well, continue to the pump house, and on to the distribution system. Include each branch line in the distribution system, and label each branch line junction. These junction points will be referenced in Worksheet 5-1.

(See Example 5-1 in Section 5.0 of the *Group B Water System Design Guidelines*.)



5.2 Complete Worksheet 5-1 (See Example 5-1 in Section 5.0 of the *Group B Water System Design Guidelines*.)

Total Dynamic Head Calculation												
Friction Head Calculation								Static Head Calculation, Assume top of well casing elevation is 0 ft.			Min. Pressure Head, ft	Min. Total Dynamic Head, ft
Pipe Segment	From	To	Pump or Flow Rate, gpm	Pipe Size, inches	Friction Loss per 100 ft	Pipeline Length, ft	Pipe Segment Friction Loss, ft	Top of well casing to water while pumping, ft	Ground Elev. at “to”	Elevation difference, ft		
1	Well pump	Top of well casing									69	
2	Top of well casing										69	
3											69	
4											69	
5											69	
6											69	
7											69	
8											69	
9											69	

1. With a simple system consisting of only a well pump and bladder tanks, the well pump is the only pump in the system. Without a storage tank, the well pump must generate enough flow and pressure to supply at least the PHD, and to provide at least 30 psi to each customer connected to the distribution system during PHD conditions.
2. For the segment that includes the well house, add 10 feet of friction loss to account for losses related to fittings and valves. If you intend to use a CSV, add additional friction loss per manufacturer’s data (See Section 5.0 of the *Group B Water System Design Guidelines*).
3. Total the “pipe segment friction loss” for each pipe segment + “elevation difference” + “minimum pressure head” values. The highest total dynamic head (TDH) is the minimum pressure, expressed in feet of head that the well pump must generate while pumping the peak hourly demand. You may wish to select a pump with a TDH greater than the required minimum.

5.3 Summary of Well Pump Selection

Cycle Stop Valve (CSV) incorporated in design: _____ Yes _____ No

Variable frequency drive well pump(s) incorporated in design: _____ Yes _____ No

<u>Pump Design Parameter</u>	<u>At well pump “on”:</u>	<u>At well pump “off”:</u>	<u>Comment</u>
Pressure switch settings or Reservoir level control	_____ psi _____ ft	_____ psi _____ ft	If well pumps to bladder tanks If well pumps to atmospheric reservoir
Discharge rate	_____ gpm	_____ gpm	
Total Dynamic Head	_____ feet	_____ feet	

Well pump setting (depth) below top of well casing: _____ feet

Attach well pump catalog information with your design submittal:

- Pump curve (or table showing discharge head and corresponding discharge flow)
- Identify the pump “on” and pump “off” operating points on the pump curve
- Pump manufacturer and pump model number
- Pump horse power

5.4 Bladder Tank Selection (for well pump or booster pump)

Follow the design guidance in Section 5.1 of the *Group B Water System Design Guidelines* for bladder tank selection. If the design includes a cycle stop valve, see the design guidelines Appendix G.

Summarize the bladder tank selection:

Size of bladder tanks _____ gallons
 Number of tanks _____ tanks
 Pre-charged pressure _____ psi

Use the space below to show your calculations (Equation 5-2) for selecting bladder tanks:

5.5 Well and pump house detailed drawings and specifications

Attach a copy of the well and pump house detailed drawings and specifications. The minimum scope of this information is in Sections 5.2 and 5.3 of the *Group B Water System Design Guidelines*.

6.0 Piping and Distribution System

6.1 Summary of pipe design

Distribution system pipe size and material specified:

(For example, *1½ to 3-inch ASTM D 1785 Schedule 40 PVC*)

Minimum pipeline depth of bury specified:

(For example, *No less than 48 inches from finished grade*)

Pipeline hydrostatic pressure testing specification:

(For example, *APWA/WSDOT (2012) Section 7-11 ... minimum 200 psi*)

Pipeline disinfection specification:

(For example, *APWA/WSDOT (2012) Section 7-11*)

Private property easements required?

Required (Design drawings must identify the location and dimension of these easements)

Not required

6.1 Service meters

Service meters:

Provided at each connection

Not provided at each connection

6.3 Cross connection control

Are there any existing or proposed cross connections?

Yes (If yes, attach a description of the cross connection and how the cross connection will be controlled or eliminated)

No

6.4 Distribution system detailed drawings and specifications

Attach a copy of the distribution system detail drawings and specifications (See Section 6.10 of the *Group B Water System Design Guidelines*).

7.0 Atmospheric Storage Tank

7.1 Determining need for an atmospheric storage tank

If any of the following conditions apply to the design of the new or expanding Group B water system, an atmospheric storage tank must be provided (Check all that apply.):

- Yes The peak hourly demand is greater than the selected well pump can deliver at the pump “on” setting.
- Yes The local fire authority requires the Group B water system to provide fire suppression capacity, and the source of supply cannot match the needed fire flow.
- Yes The location of the Group B water system is subject to the Public Water System Coordination Act, it must provide a minimum fire flow, and the source of supply cannot match the needed fire flow.
- Yes The designer wishes to provide standby storage or fire suppression capacity.

Use the space below (or a separate sheet of paper) to show your calculations for sizing the storage tank and establishing the elevation of the tank bottom and tank overflow. See Chapter 7 and Equation 7-4 in the *Group B Water System Design Guidelines*.

Operating storage:

Equalizing storage:

Standby storage:

Fire suppression storage:

Dead storage:

7.2 Storage tank detailed drawings and specifications

Attach a copy of the storage tank detail drawings and specifications. (See Section 7.6 of the *Group B Water System Design Guidelines*.)

8.0 Booster Pumps

8.1 Booster pump selection

Summarize the following booster pump design information:

Number of booster pumps: _____

Cycle Stop Valve (CSV) incorporated in design:

_____ Yes _____ No

Variable frequency booster pump drive pump(s) incorporated in design:

_____ Yes _____ No

Booster Pump 1

<u>Pump Design Parameter</u>	<u>At well pump “on”:</u>	<u>At well pump “off”:</u>
Pressure switch pressure setting	_____ psi	_____ psi
Discharge rate	_____ gpm	_____ gpm
Total Dynamic Head	_____ feet	_____ feet

Attach booster pump catalog information with your design submittal:

- Pump curve (or table showing discharge head and corresponding discharge flow)
- Identify the pump “on” and pump “off” operating points on the pump curve
- Pump manufacturer and pump model number
- Pump horse power

Booster Pump 2 (if applicable)

<u>Pump Design Parameter</u>	<u>At well pump “on”:</u>	<u>At well pump “off”:</u>
Pressure switch pressure setting	_____ psi	_____ psi
Discharge rate	_____ gpm	_____ gpm
Total Dynamic Head	_____ feet	_____ feet

Attach booster pump catalog information with your design submittal:

- Pump curve (or table showing discharge head and corresponding discharge flow)
- Identify the pump “on” and pump “off” operating points on the pump curve
- Pump manufacturer and pump model number
- Pump horse power

8.2 Booster pump station detailed drawings and specifications

Attach a copy of the booster pump station detail drawings and specifications. (See Sections 5.2, 5.3, and 8.0 of the *Group B Water System Design Guidelines*.)

9.0 Secondary Contaminant Treatment Design

If treatment for a secondary contaminant (such as iron or manganese) is required, provide the following information.

Contaminant(s) to be treated: _____

Treatment device: _____

Manufacturer's name: _____

Model: _____

Capacity (gpm): _____

Capacity (gpd): _____

Removal efficiency: _____

Concentration in well: _____ mg/l

Expected concentration after treatment: _____ mg/l

Attach a copy of the following information:

- Treatment process and maximum daily treated water production capacity.
- Hydraulic considerations and headloss calculations.
- Manufacturer's catalog information showing the treatment system is appropriate for removing the contaminant, based on the untreated water sample information from the well.
- A complete set of water quality data necessary to assess and confirm the effectiveness of the proposed treatment, based on the unique water quality characteristics of the well to be treated.
- Residual disposal volume, disposal permit(s) (if required), and plan for residual disposal.
- Manufacturer's recommended operations and maintenance procedures.
- A list of all chemicals needed for normal operation and maintenance (if any).
- Materials safety data sheet information on all chemicals needed.
- Manufacturer's recommended field water quality testing (if any).

10.0 Financial Viability

10.1 Financial Viability Worksheet

The goal is to establish plans, policies, and procedures that give the system owner(s) the ability to obtain enough funds to cover the total cost of operating and maintaining a safe, reliable water system on a continuing basis. Rates and other revenue should be adequate to cover all anticipated expenses. See Chapter 10 of the *Group B Water System Design Guidelines*.

TOTAL EXPENSES	1st Yr.	2nd Yr.	3rd Yr.	4th Yr.
1. Wages & Benefits (Incl. SMA costs)	\$	\$	\$	\$
2. Electricity & other utilities	\$	\$	\$	\$
3. Chemical & Treatment	\$	\$	\$	\$
4. Monitoring Costs	\$	\$	\$	\$
5. Materials & Supplies	\$	\$	\$	\$
6. Repairs and Parts	\$	\$	\$	\$
7. Emergency Reserve Contribution	\$	\$	\$	\$
8. Asset Replacement Reserve Contribution	\$	\$	\$	\$
9. Principal & Interest Payments (For outstanding loans)	\$	\$	\$	\$
10. Taxes and Assessments	\$	\$	\$	\$
11. Insurance and Misc. Expenses	\$	\$	\$	\$
12. Total Expenses (Add lines 1 to 11)	\$	\$	\$	\$
TOTAL REVENUE FROM SOURCES OTHER THAN WATER RATES				
13. Hook Up and Other User Fees	\$	\$	\$	\$
14. Interest Earned	\$	\$	\$	\$
15. Other Revenue	\$	\$	\$	\$
16. Total Revenue (Add lines 13 to 15)	\$	\$	\$	\$
WATER RATE CALCULATIONS				
17. Remaining Revenue Required (Line 12 minus Line 16)	\$	\$	\$	\$
18. Number of Connections	\$	\$	\$	\$
19. Average Water Rate (Line 17 divided by Line 18)	\$	\$	\$	\$